

COUNTY OF TEHAMA DEPARTMENT OF BUILDING & SAFETY

Skip Perry, Building Official
P.O. Box 458
Red Bluff, CA. 96080
(530)527-7002 (530)527-2655 fax



444 Oak St. 2nd Floor Room H
Red Bluff, CA. 96080
Tehama County Courthouse Annex
e-mail: building@co.tehama.ca.us

MANUFACTURED HOME ELECTRICAL CONNECTION

June 21, 2007

When a Manufactured Home, Mobile Home, or Commercial Modular is placed on a foundation system per Section 1333.5 of Title 25 of California Code of Regulations the utility connections shall be governed by and be in compliance with the California Plumbing Code and the California Electric Code.

Section 550.32 of the California Electric Code states:

- (A) **Mobile Home Service Equipment.** The mobile home service equipment shall be located adjacent to the mobile home and not mounted in or on the mobile home. The service equipment shall be located in sight of and not more than (30 ft) from the exterior wall of the mobile home it serves. The service equipment shall be permitted to be located elsewhere on the premises, provided that a disconnecting means suitable for service equipment is located in sight from and not more than (30 ft) from the exterior wall of the mobile home it serves. Grounding at the disconnecting means shall be in accordance with Section 250.32 of the California Electric Code.

It will be **permissible** for the service equipment to be attached to the mobile home only if it is installed at the factory. **[AS A REMINDER A PERMIT IS REQUIRED FROM HCD IF ANY MODIFICATION OR ADDITION IS MADE TO THE ELECTRICAL SERVICE IN A MOBILE HOME (this includes wires, breakers or conduit for well pumps, garage, shop, etc.)]**

Skip Perry
Building Official